

## Ameya Agencies



**ENGINEERING & FIRE SAFETY SOLUTION** 

## Inspection certificate of fire prevention and life safety measure

(FORM-B)

License no - MFS - LA/2021/RF-155 Ref No . - AA/21-22/KR- 030
MFS - LA/RD-323 Date - 23-12-2021
MFS - LA/2020/RP-74

To
The Chief Fire Officer,
MC Gondia

Certified that We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the Building premises of the namely

Name of Building and Address:

" Dhote Bandhu Science College "
Bhandkar Road, Rail Toli,
Gondia.

We further certify that these installations in the above mentioned Residential buildings are maintained in good repair and efficient conditions during the period 1st Jan 2022 to 30th June 2022 as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah III of 2007.).

The details of the inspection of installations carried out by us are mentioned in the report appended herewith.

For Ameya Agencies





## Ameya Agencies



**ENGINEERING & FIRE SAFETY SOLUTION** 

## The details of the inspection of installation carried out by us.

Sr .No	Description	Work Done	Qty	Remarks
1	ABC store pressure type fire extinguisher	Refilled and Checked by us.	25 nos	All fire extinguisher are 10. working good condition
2	Hose reel drum with hose pipe & pvc	Checked by us	06 nos.	working in good condition.
3	nozzle.	Checked by us	06 nos	working in good condition
	Hydrant valve 63 mm.	Checked by us	06 nos.	working in good Const 1 con
4	Hose Pipe 63mm x15 mtr length	Checked by us	06 nos	working in good condition
5	Hose Box	Checked by us	06 nos.	working in good condition
7	Branch Pipe 63 mm dia Fire Pump 5 HP	Checked by us	01 nos.	At the time of trail, pump is working properly with the help of electric supply and with the help of generator.
8	Fire Bus	Citered by us	01 nos	working in good condition

For Ameya Agencies

YA AC

Arvind Khobe

Signature